Green Audit Report

For

SCMS School of Engineering and Technology, Karukutty



Prepared by



SCMS Water Institute (SWI),

SCMS School of Engineering and Technology, Karukutty, Ernakulam

January 2022

Contents

- 1.0 Introduction
 - 1.1 Background
 - 1.2 Green Audit
 - 1.3 Methodology
- 2.0 Water Audit
- 3.0 Energy Audit
- 4.0 Solid Waste Audit
- 5.0 Summary of Findings & Recommendations

1.0 Introduction

1.1 Background

SCMS School of Engineering and Technology (SSET) is a technological institute in Kerala which offers graduate and postgraduate programs in engineering and technology. The college was established in 2001 on a 29-acre (117,359 m²) campus at Karukutty, Ernakulam District, Kerala. The campus has a total built up area of about 1,57,440 square feet which includes one administrative block, two academic blocks, ladies hostel, junior men's hostel, laboratories, canteen and auditorium. Senior men's hostel is outside the campus. The campus has strength of 210 staff and 1650 students, out of which 629 reside in the campus. The canteen is equipped to provide food for about 700-800 persons per day.

The major source of water for the campus is the bore wells. Electricity for the entire campus is provided by KSEB. In 2019 SCMS has applied for installation of solar panels with a capacity to generate 250 kW energy under scheme 1 and 2 of KSEB; the project is not yet implemented due to covid pandemic. The campus houses an effluent treatment plant and a power house with DG sets as backup during power failures.

Key facts about the site are provided in Table 1.1. Figure 1.1 provides a Google Earth bird's eye view of the area and location of the SSET campus.

Table 1.1 Key facts about the site

Name of Project	SCMS School of Engineering and Technology
Address	Karukuty, Angamaly, Ernakulam
Average Annual Rainfall	3159.76 mm
Water source	Bore well
Water harvesting system	Roof top system that collects rain water falling on roof and then send it for well recharge
Wastewater treatment system	Two stage anaerobic filter and Moving Bed Biofilm Reactor
Water harvesting potential	~7600 kilo litres
Average daily water demand	~170 kilo litres
Average daily energy demand	~7866 Units
Average daily waste produced	265 kg
Total built-up area	1,57,437.41 square feet




Figure 1.1 Location of SSET, Karukutty, Ernakulam




Figure 1.2 Detailed site plan of SSET campus

1.2 Green Audit

Green audit is the process of assessing the environmental impact of an organization, process, project, product etc. Green Audit can be defined as a basic management tool comprising a systematic, documented, periodic and objective evaluation of how well environmental organisations, management systems and equipment are performing. The aim of the audit is to facilitate management control on environmental practices and to enable the organization to assess compliance with its policies including meeting regulatory requirements.

1.3 Methodology

Key components of green audit conducted at SSET, Karukutty campus included

(i) Pre-audit planning

- a. Preliminary literature review of concepts and methodologies related to green audit
- b. Discussion with the management staff on various systems installed in the campus
- c. Awareness creation and interaction with the staff and student on the concept of green audit
- d. Walk through the entire campus to understand the nature of water use, energy use and waste management systems in the campus

(ii) Data collection

- a. Development of questionnaire format to identify all water/energy using fixtures/ equipments and examine water/energy use patterns for individual buildings in the campus
- b. Collection of secondary data from compilation of electricity bills, collating records of pumps, generators, water quality analysis reports, waste water treatment equipment details, civil and electrical drawings etc.
- c. Semi structured interview with maintenance manager, technicians, plumber, and housekeeping staffon current situation and the past trends in water consumption, electricity consumption, waste management, wastewater generation etc.

(iii) Data processing and analysis

The existing trends and patterns in water usage, energy usage and waste generation and management is analysed in this step from the data collected in the previous step.

(iv) Audit recommendations and reporting

Based on the understanding from green audit, recommendations are given to improve the existing environmental performance of the campus and are documented in a report format.

2.0 Water Audit

A water audit is a systematic review of a site to identify opportunities to improve its water use efficiency. The site may be a public water utility, facility (institutional or commercial properties like malls, office, schools etc.) or a household. Audit recommendations are developed based on surveys and assessments of water-using hardware, fixtures, equipment, landscaping, and management practices at the site. Water audit involves tracking, assessing and validating all components of flow from the site of withdrawal or treatment through the water distribution system and into the consumer's properties. Water auditing examines the major areas of water use, including human consumption, personal hygiene & sanitation, washing, cleaning, laundry, gardening etc. Water auditing is an ongoing process and rarely stays consistent in a site or system over time. Therefore in order to gauge progress from adopted water conservation and cutbacks, water audit should be performed on a regular basis. In addition it provides convincing overview of the water use trends, effectiveness of conservation measures and potential cost and water savings.

2.1 Water supply

Around 170 kilo litres of water is used in the campus daily. Source of water for the entire campus is bore wells. There are four bore wells in the campus. Three bore wells are used to meet the water demand of the campus including canteen and hostels and one bore well is used exclusively for senior men's hostel which is outside the campus. Moreover around 2000 litres of water per month is used for drinking purpose in the academic blocks. Table 2.1 shows the characteristics of water from the bore well of the campus.

Table 2.1 Drinking water quality parameters (As per IS 10500-2012)

PARAMETERS	UNIT	VALUE	DESIRABLE	RELAXABLE
рН		7.1	6.5 - 8.5	No relaxation
Odour		Odourless	Unobjectionable	
Taste		Tasteless	Unobjectionable	
Turbidity	NTU	0.2	5	10
Total Hardness (as CaCO ₃)	mg/l	60	300	600
Total Dissolved Solids	mg/l	118	500	2000
Iron (as Fe)	mg/l	0.12	0.3	1.5
Chlorides (as Cl)	mg/l	28	250	1000

2.2 Water use diagram

SSET campus were closed due to Covid-19 from March 2020 to August 2021. Classes where conducted in online mode and only few staff were present at the campus due to Covid protocol restrictions. Due to these cant able to conduct a survey using questionnaire; so the water consumption is calculated based on the semi structured interview conducted with technicians and staff in the campus. Figure 2.5 shows the water usage by various activities of SSET campus based on the survey. It can be seen that toilet flushing (27%), floor wash (21%) and bathing (17%) are the activities that dominates water usage. Figure 2.6 shows the water consumption by different blocks of SSET campus. There were no leakages that were observed or reported during the audit exercise at SSET.




Figure 2.1 Activity wise water consumption at SSET




Figure 2.2 Composition of total water (170 kilo litres) use by different blocks of SSET



Figure 2.3 Interviewing hostel staff for water demand calculation

2.3Water circuit diagram


Water circuit diagram shows how the water flows from the source to the consumers. It also identifies the position of pumps and tanks. Based on the walk through surveys, discussions with staff and managing committee, a water circuit diagram has been prepared and is shown in the figure 2.4.

The source of the water for the entire campus is three bore wells. From the bore well near Academic block-I, the water is pumped into an underground collection tank having a capacity of 1, 10,000 L using two 5HP pumps. From there, the water is pumped to the two overhead

tanks of academic block -I having a capacity of 50,000 L each. From these tanks, the water is distributed to the academic block–II, ladies hostel, junior men's hostel, canteen and laboratories using the natural flow.

From the bore well near administrative block, the water is pumped directly to two overhead tanks of capacity 1000 L each and one overhead tank of capacity 2000 L using two 5HP pumps. The water from these tanks is used by the administrative block alone.

From the bore well near senior men's hostel, water is pumped to two overhead tanks of capacity 25,000 L each using two 5HP pumps. Presently this water is used exclusively by the senior men's hostel. Among the 2 pumps in all cases, one serves as a stand-by.






Figure 2.4 Water distribution network of SSET campus

2.4 Wastewater sources

One administrative block, two academic blocks, five laboratory blocks, one canteen, two hostels and one auditorium is present in the campus. The toilets, washbasins and urinals of two academic blocks, various laboratories, two hostels and the wastewater from cooking, dishwashing etc. from the canteen are the major wastewater sources of ETP. The wastewater generated from the administrative block alone is treated using a separate septic tank.

2.5 Waste water collection network

The waste water collection network shows the path flow of the waste water from the various blocks into the Effluent Treatment Plant. The sullage from canteen is passed through an oil trap and is then collected in a collection tank. The sewage from academic block- I, academic block- II, ladies hostel and junior men's hostel is also collected in the collection tank, from where it is sent to the ETP. The sewage from administrative block alone is treated by a separate septic tank.




Figure 2.5 Wastewater circuit diagram of SSET campus

2.6 Waste water treatment facility

The ETP in the campus incorporates various treatment units that can be adopted in the treatment of waste water. It includes the tertiary treatment of sewage using Reverse Osmosis and UV sterilization unit, so that other than irrigation purposes the treated wastewater can be used for drinking purposes. A process diagram of the effluent treatment plant in the campus is shown in figure 2.1. The effluent treatment plant in SSET campus consists of the following units:

- Screen and Oil Trap (OT)
- Septic Tank
- Two staged anaerobic filter
- Moving bed bio-film reactor (MBBR)
- Secondary clarifier
- Disinfection Tank (DT)
- Pressure sand filter (PSF), Activated carbon filter (ACF)
- Reverse Osmosis unit (RO)
- UV sterilization unit




Figure 2.6 Process diagram of ETP at SSET campus



Figure 2.7 Green audit team inspecting the ETP of SSET campus



Figure 2.8 Reverse Osmosis unit in ETP of SSET campus



Figure 2.9 Green audit team inspecting the clarifier of ETP

Table 2.2 Characteristics of influent and effluent of ETP, SSET campus

Parameter	Influent of STP	Outlet of STP	Standard (Environmental (Protection) Rules, 1986)	Standard BIS (ISI)
pH	6.6	6.9	5.5 - 9.0	5.5 - 9.0
Temperature (°C)	27.7	27.6	NA	NA
TDS (mg/l)	605	404	NA	2100
Suspended Solids (mg/l)	190	20	200	NA
Free Chlorine (mg/l)	0	0.7	NA	NA
Oil & Grease (mg/l)	51.5	0	10	30
COD (mg/l)	352	70	NA	NA
BOD ₅ at 20°C (mg/l)	205	30	100	500
Sulphate (mg/l)	12.3	4	NA	1000
Phosphate (mg/l)	33	5.7	NA	NA

2.7 Rain water harvesting status and potential

Rain water harvesting is the accumulation and deposition of rainwater for reuse on site rather than allowing it to runoff. Proper rainwater harvesting can conserve huge amount of fresh water. In the campus, presently rain water harvesting is done for Administrative block, Academic block–I and senior men's hostel.

Rain water collected in the open terrace of administrative block is carried to a well and a bore well for ground water recharge. Inorder to prevent aquifer contamination, the rainwater is passed through a pressure sand filter before passing into the bore well. Rain water collected by the roof of academic block-I is carried to a tank at ground level. Presently, this water is used for various construction activities that are going on in the campus.

The total roof area available = 3413.31 sq meter

Average annual rainfall at Angamaly = 3.2 meters

(Assuming 70% of the rain water collected is harvested)

Thus, the total potential for rainwater collection = 7600 KL

Inclusion of the roof area of academic block- II, canteen and hostels can increase the rain water being harvested.



Figure 2.10 Salient locations of well recharging system at SSET




Figure 2.11 Schematic diagram showing recharge to bore well from roof top at SSET



Figure 2.12 Rain water collected at rooftop is treated using Pressure sand filter before taken for bore well recharge




Figure 2.13 Schematic diagram showing recharge to open well from roof top at SSET



Fig. 2.14 Rain water collected at rooftop directed open well for recharging

3. Energy Audit

An energy audit is an inspection, survey and analysis of energy flows for energy conservation in a building, process or system to reduce the amount of energy input into the system without negatively affecting the output(s).Reducing energy consumption while maintaining or improving human comfort, health and safety are of primary concern. The primary objective of Energy Audit is to determine ways to reduce energy consumption per unit of product output or to lower operating costs. Energy Audit provides a "benchmark" (Reference point) for managing energy in the organization and also provides the basis for planning a more effective use of energy throughout the organization.

3.1 General descriptions about energy consuming appurtenances/activities in the campus

There is an administrative block, two academic blocks, various engineering laboratories, canteen, Effluent Treatment Plant, ladies hostel and junior men's hostel within the campus. The senior men's hostel is located outside the campus.

The Administrative Block facilitates a Principal's room, guest room, office room, mini conference hall, placement cell, cafeteria, faculty room, and main computer lab, which are fully air conditioned. It also provides space for first year B.Tech classes, M.Tech classes, MCA classes, faculty rooms, manager's room, examination cell, reading room, exhibition gallery, drawing halls and PG computer lab. A gym is also functioning in the ground floor.

All the rooms are provided with ceiling fans and tubes. Projectors are used mainly by PG classes. Toilets are provided in each floor and are lighted with tubes and fluorescent lamps. Since the building has good ventilation and natural lighting, no artificial lighting is required for the corridors.

The Academic block-I facilitates B.Tech classes, faculty room, SCMS Water Institute, CAD lab, 3D printer lab, Computer lab, seminar hall, Communication & Microwave Lab, Digital and Advanced Microprocessor Lab, and Electronic Circuits Lab.

The Academic block –II facilitates B.Tech classes, faculty rooms, Survey lab, Transportation lab, Geotechnical lab, Environmental engineering lab, Computer lab, Basic EEE Measurement Lab, Electrical workshop, and Control and Power Electronics Lab.

The laboratory blocks include Automobile workshop, Strength of Materials and Material Testing lab, Basic Workshop, Machine Tools lab, Hydraulics lab, Heat Engine/ Heat Transfer Mechanical Engineering lab, and Electrical Machines lab.

Ladies hostel has 3 floors with 42 rooms in each floor. Presently there are 370 inmates. Each room can accommodate 3 students. There are 2 tubes, one ceiling fan and 2 plug points in each room. Apart from that there is a wardens' room, a study room and one computer room having 4 computers with LCD monitors...Two washrooms are provided in each floor which is equipped with heaters. Corridors are artificially lighted with fluorescent lamps.

Junior men's hostel has a total of 64 rooms in 3 floors. Presently 149 inmates are occupied in 57 rooms. Each room has 2 tube lights, 1 fan and 2 plug points. Wash rooms are provided on each floor. Terrace is now converted to a common study area with 6 tubes and 8 fans.

Senior men's hostel has 4 floors. All rooms are bath attached. Each room has 2 fans, 2 tubes and 2 plug points. Presently 36 rooms are occupied by 274 inmates.

There is a 24 hours working Effluent Treatment Plant in the campus which has a capacity to treat one lakh litres of waste water per day. Effluent from all the blocks except administrative block is treated in the ETP.

3.2 Methodology

- Data collection
 - Walk through audit- collection of type and number of energy consuming appurtenances
 - Informal interviews with staffs and students- usage pattern, lab and class timings, office working hours
- Data analysis- Identification of major energy consuming areas
- Identification of energy conservation opportunities

3.3 Energy consumption status of the campus

Energy consumption pattern of each building in the campus has been evaluated. Calculation criteria are described below.

3.3.1 Administrative Block

Administrative block consists of G + 5 floors. The elevator of this block consumes around 120kWh per day. Detailed power consumption of each floor is given in the below tables.

GROUND FLO	GROUND FLOOR									
Room	Tube	Fan	Computer	Power consumption/month (kWh)						
FAB lab	20	10	5	282.3						
Class room	7	6		79.488						
Class room	7	6		79.488						
Class room	7	6		79.488						
Class room	7	6		79.488						

Examination cell	24	11+ 2 exhaust	70.9
Toilet	4		24.192
Total			695.34

GYMNASIUM			
Equipment	No:	Power (kW)	Power consumption/month (kWh)
Sports Treadmill	1	0.9	54
Sports Recumbent Bike	1	0.75	11.25
Sports Upright Bike	1	0.75	11.25
Elliptical Trainer	2	0.75	22.5
Fan	3 + 2 exhaust	0.05	22.5
Tube	14	0.036	45.36
Total			166.86

FIRST FLO	OR									
Room	Tube	T.V	Printer	CFL	Projector	Fan	Computer	AC	Others	Power consumption/ month (kWh)
Reception	8	1				1	1			48.72
Principal's room	12	1	1		1	1	1	3 t		615.12
Guest room	6							3 t		38.16
Office	15			3			8	8.5 t	1 photostat, 1 printer, telecom,1 scanner	1919.4
Mini conference	12			6				8.5 t		225.162
Placement	8						2	3 t		1169.28
Cafeteria	6							3 t		36.81
Staff room	12						27	8.5 t	2 printer	1873.256
Manager's room	2					1	1			34.75
Class room	8					8				99.072
Class room	8					8				99.072
Class room	8					8				99.072
Class room	8					8				99.072
Class room	8					8				99.072
Staff toilet	2			3						19.656

Total						6514.986
Ladies toilet	4		6			39.312

SECOND F	LOO	R							
Room	Tube	CFL	Fan	Computer	Projector	Printer	AC	Others	Power consumption/month (kWh)
Computer Lab Main	86			11 5		2	4*8.5 t + 1*1.5 t	4 server, 12 LAN switches, 1 dot- matrix, 1 acer	153379.72
Conference hall	36			1	1		4*8.5 t	8speaker	893.466
Classroom	9		7		1				76.656
Classroom	9		7		1				76.656
Classroom	9		7		1				76.656
Classroom	9		7		1				76.656
Gents staff toilet	2	3	1						28.056
Gents toilet	4	3	1			·			40.152
Total									154648.018

THIRD FLOO	OR			
Room	Tube	Projector	Fan	Power consumption/month (kWh)
Classroom	9	1	7	113.232
Classroom	9	1	7	113.232
Classroom	9	1	7	113.232
Classroom	9	1	7	113.232
Classroom	6	1	6	86.688
Classroom	6		5	78.288
Classroom	20		17	47.1
Drawing hall	16		13	176.544
Ladies toilet	2			1.519
Ladies room	2		2	0.924
Total				843.991

FOURTH FLOOR									
Room	Tube	CFL	Fan	Printer	Computer	Projector	Power consumption/month (kWh)		
Faculty room	24		12	2	27		249.984		
PG lab	42		5		60		223.584		
Classroom	6		7			1	95.088		
Classroom	9		7			1	113.232		
Classroom	9		7			1	113.232		
Classroom	9		7			1	113.232		
Classroom	9		7			1	113.232		
Classroom	9		7			1	113.232		
Classroom	6		6			1	86.688		
Girl's common room	8		3				2.408		
Ladies toilet	2	3	2 exhaust				1.519		
Ladies staff toilet	2	4					0.924		
Total							1226.355		

FIFTH FLOOR					
Room	Tube	Fan	Projector	Computer	Power consumption/month (kWh)
Classroom	85	47			294.624
Seminar hall 2	18	13	1		113.232
Boys common room	9	7			108.576
Counselling Centre	6	6		1	12.384
Store room	8	4			134.4
Seminar hall 3	37	14	1		178.949
Wash room(gents)	4				1.519
Staff toilet	2				0.924
Total					844.608

A 5 HP motor is used to draw water from bore well -2 to the overhead tanks of administrative block. Total power consumption by the motor is 13kWh/day; i.e., 390kWh/month.

POWER CONSUMPTION TREND OF ADMINISTRATIVE BLOCK




Figure 3.1 Power consumption trend of administrative block

From the pie chart above it can be seen that the major power consuming equipment in administrative block is air conditioner (49%).

3.3.2 Academic Block - I

The Academic Block- I consists of G + 2 floors.

GROUND FLO	GROUND FLOOR							
Room	Tube	Fan	Computer	Exhaust fan	AC	Printer	Projector	Power consumption/month (kWh)
Mech faculty	20	12	30	2		1		655.65
Mech HOD	3	1	1		2*1.5t			711.984
SWI	12	5	4	2				141.83
CAD lab	36	14	38	2				988.992
Class room	8	5					1	94.784
Class room	8	5					1	94.784
Class room	8	5					1	94.784
Class room	10	5					1	106.88
Class room	10	5					1	106.88
3D printer lab	4				2*1.5t			628.992
Dept. of Sports & Physical Education	1	1						12.384
Total								3637.44

FIRST FLOOR							
Room	Tube	Fan	Computer	projector	AC	Power consumption/month (kWh)	
Class room	4	5		1		99.792	
Faculty (EC)	4	4	1			98.112	
Class room	4	5		1		99.792	
Automobile	4	5				99.792	
Staff	4	4	1			98.112	
Class room	4	5		1		99.792	
Faculty (ME)	4	4	1			98.112	
Class room	4	5		1		99.792	
Computer lab (1 & 2)	32		56		5* 1.5t	4161.024	
Computer lab - 5	18		50		3*1.5t	2923.776	
Ladies toilet	2					12.096	
Total						7889.456	

SECOND FI	SECOND FLOOR							
Room	Tube	Fan	Projector	Others	Power consumption/month (kWh)			
Class room	4	5	1		69.192			
Class room	4	5	1		69.192			
Class room	4	5	1		69.192			
Class room	4	5	1		69.192			
Class room	4	5	1		69.192			
Gents toilet	5				30.24			
Seminar hall	9	10	1	1mic, 5*1.5t A.C	301.02			
Total					677.22			

Communication & Microwave Lab						
Equipment	No:	Power (kW)	Power consumption/month (kWh)			
Digital storage oscilloscope		0.05	108			
3 MHz multiwaveform signal generator with modulation	15	0.1	216			
DC regulated power supply single	15	0.03	64.8			
DC regulated power supply dual	15	0.06	129.6			
Microwave bench	4	0.1	57.6			
Universal IC tester	1	0.1	14.4			
Soldering iron	1	0.05	2.4			
Table lamp	1	0.02	0.48			
Computer	1	0.24	1.8			
Tube	8	0.036	41.472			
Fan	8	0.05	57.6			
Total			694.152			

Digital and Advanced Microprocessor Lab					
Equipment	No:	Power (kW)	Power consumption/month (kWh)		
Digital IC logic trainer	15	0.05	108		
Microprocessor 8085	15	0.05	108		
DC regulated power supply single	15	0.06	129.6		
DC regulated power supply dual	15	0.05	108		
Micro controller kit	5	0.045	32.4		
CR oscilloscope	1	0.05	7.2		
Digital IC tester	1	0.075	10.8		
Universal programmer and IC tester	1	0.05	7.2		
Soldering iron	1	0.05	7.2		
Table lamp	1	0.02	2.88		
Tube	4	0.036	20.736		
Fan	4	0.05	28.8		
Total			570.816		

Electronic Circuits Lab					
Equipment	No:	Power (kW)	Power consumption/month (kWh)		
Oscilloscope	15	0.045	56.7		
Function generator	15	0.025	31.5		

DC regulated power supply single	15	0.03	37.8
DC regulated power supply dual	15	0.06	75.6
Tube	8	0.036	24.192
Fan	8	0.05	33.6
Total			259.392

A 5 HP pump is used to draw water from the bore well - 2 to the collection tank and another 5 HP pump is used to pass this water to the overhead tanks of Academic Block- I. The total power consumption by the motors is 97kWh per day; i.e., 2910kWh per month

3.3.3 Academic Block –II

GROUND FLOOR							
Survey Lab							
Equipment	No:	Power (kW)	Power consumption/month (kWh)				
Tube	12	0.036	20.736				
Computer	1	0.24	12.48				
Fan	6	0.05	14.4				
Total			47.616				

Transportation Lab							
Equipment	No:	Power (kW)	Power consumption/month (kWh)				
ductility testing machine	1	3.2	32				
abrasion testing machine	1	2	20				
CBR testing apparatus	1	1.1	11				
Penetrometer	1	0.025	0.125				
Tube	12	0.036	51.84				
Fan	6	0.05	36				
Total			150.965				

Geotechnical lab						
Equipment	No:	Power (kW)	Power consumption/month (kWh)			
Light compaction test apparatus	10	0.372	3.72			
Sieve shaker	1	0.18	0.18			
Electronic weighing balance 2kg	1	0.015	0.045			
Electronic weighing balance 10kg	1	0.015	0.045			
Hot air oven	1	2	40			
Vane shear apparatus	1	0.372	0.372			
Direct shear apparatus	1	0.372	0.372			

Total			76.786
Fan	6	0.05	14.4
Tube	10	0.036	17.28
Unconfined compression tester	1	0.372	0.372

Environmental Engineering Lab							
Equipment	No:	Power (kW)	Power consumption/month (kWh)				
Hot air oven	1	2	20				
BOD incubator	1	1.5	15				
Digital spectrophotometer	1	0.006	0.03				
Autoclave	1	3	30				
Magnetic stirrer	1	0.015	0.075				
Refrigerator	1	0.04	30				
Jar test apparatus	1	0.037	0.222				
Single distillation unit	1	3	72				
Electronic weighing balance	1	0.015	2.16				
Tube	12	0.036	43.2				
Fan	4	0.05	20				
Total			160.687				

FIRST FLOOR						
Computer Lab						
Equipment	No:	Power (kW)	Power consumption/month (kWh)			
Computer (LCD)	80	0.24	460.8			
20 port network switches	4	0.28	188.16			
Printer	2	0.1	0.1			
Managed network switch	4	0.35	235.2			
Tube	14	0.036	72.576			
Projector	1	0.20	4.8			
Fan	14	0.05	100.8			
Total			1062.436			

Basic EEE Measurement Lab						
Equipment	No:	Power (kW)	Power consumption/month (kWh)			
Miscellaneous			10			
Tube	10	0.036	51.84			
Fan	5	0.05	36			
Total			97.84			

Electrical Workshop			
Equipment	No:	Power (kW)	Power consumption/month (kWh)
Tube	7	0.036	25.2
Fan	4	0.05	20
Total			45.2

Control and Power Electronics Lab							
Equipment	No:	Power (kW)	Power consumption/month (kWh)				
Amplydyne	1	3.7	29.6				
CR Oscilloscope	8	0.045	252				
Trainer's kit	5	0.1	12				
Microprocessor kit	1	0.12	192				
Computer (LCD)	5	0.24	172.8				
Computer (CRT)	1	0.28	40.32				
Tube	13	0.036	67.392				
Fan	6	0.05	43.2				
Total			809.312				

SECOND FLOOR							
Room	Tube	Fan	Computer	Power consumption/month (kWh)			
EEE faculty	11	7	6	165.648			
CE faculty	10	7	6	159.36			
EEE faculty	5	4		63.84			
HOD EEE	4	4	6	98.112			
Class room	6	6		86.688			
Class room	6	6		86.688			
Class room	6	6		86.688			
Class room	6	6		86.688			
Total				833.712			

THIRD FLOOR							
Room	Tube	Fan	Computer	Power consumption/month (kWh)			
Civil faculty	6	6	9	75.744			
Class room	6	5		78.288			

Class room	6	5	78.288
Class room	6	5	78.288
Class room	6	5	78.288
Class room	6	6	86.688
Class room	6	6	86.688
Class room	6	6	86.688
Total			648.96

3.3.4 Laboratory Blocks

PRODUCTON ENGINEERING LAB							
Equipment	No:	Power (kW)	Power consumption/month (kWh)				
All grade head lathe	20	2.25	900				
CNC lathe	1	1.5	30				
CNC mill	1	1.5	30				
Mechanical Surface grinder	1	0.75	75				
Shaping machine	9	1.5	270				
Slotting machine	6	1.1	132				
Universal milling machine	2	2.25	90				
All geared slotted machine	6	1.1	132				
Tool and cutter grinding machine	1	0.37	7.4				
Geared drilling machine	1	1.1	22				
Hydraulic back saw machine	1	0.75	15				
Motorised grinder	1	0.75	15				
Drilling machine	1	0.75	15				
Fan	16	0.05	16				
Tube	66	0.036	47.52				
Total			1811.92				

HYDRAULICS LAB							
Equipment	No:	Power (kW)	Power consumption/month (kWh)				
Centrifugal pump	2	10	100				
Different pumps	1	12	60				
Total			160				

BASIC MECHANICAL WORKSHOP								
Equipment	No:	Power (kW)	Power consumption/month (kWh)					
HF Muffle furnace	1	5	100					
Grinder	1	0.375	7.5					
Circular sloth	1	1.5	30					
Cutter	1	1.5	30					
Water Filter	1	0.28	5.6					
Fan	7	0.05	7					
Tube	44	0.036	31.68					
Total			211.78					

HEAT ENGINE LAB/ HEAT TRANSFER LAB/ MECH ENGG LAB						
Equipment	No:	Power (kW)	Power consumption/month (kWh)			
Heat transfer in forced convection	1	0.21	10.92			
Emmissivity measurement apparatus	1	0.21	10.92			
Heat transfer in natural convection	1	0.21	10.92			
Thermal conductivity of insulating powder	1	0.21	10.92			
Heat transfer through lagged pipe	1	0.21	10.92			
Parallel flow / counter flow heat exchanger	1	3	156			
Refrigeration test rig	1	0.25	13			
Air conditioning test rig	1	1	52			
Hartnel governor	1	0.18	9.36			
Porter governor	1	0.18	9.36			
Gyroscope	1	0.062	3.224			
Static and Dynamic balancing	1	0.05	2.6			
Variable speed air blow motor	1	2.2	114.4			
Two stage air compressor motor	1	2	104			
Rotameter tranier	1	0.1	5.2			
Centrifugal pump	1	0.37	19.24			
Filter	1	0.23	11.96			
Tube	53	0.036	99.216			
Fan	17	0.05	44.2			
Total			698.36			

AUTOMOBILE WORKSHOP								
Equipment	No:	Power (kW)	Power consumption/month (kWh)					
Fan	17	0.05	136					
Tube	46	0.036	33.12					
Projector	1	0.204	4.08					
Total			16.13					

STRENGTH OF MATERIALS & MATERIAL TESTING LAB			
Equipment	No:	Power (kW)	Power consumption/month (kWh)
Compression testing machine 1000kN	1	0.7457	14.914
Compression testing machine 2000kN	1	1.4	28
UTM 400kN	1	0.9694	19.388

UTM 1000kN	1	2.23	44.6
Vibration machine with digital timer	1	0.3728	7.456
Sieve shaker	1	0.3728	7.456
Mixer machine	1	1.11	22.2
Tube	18	0.036	12.96
Fan	13	0.05	13
Total			169.974

ELECTRICAL MACHINES LAB			
Equipment	No:	Power (kW)	Power consumption/month (kWh)
DC compound generator	1	3.7	133.2
DC compound motor	1	3.7	133.2
DC shunt motor	1	3.7	133.2
DC series motor	1	3.7	133.2
DC series motor + DC series generator set	1	3.7	133.2
DC shunt motor + DC series generator set	1	3.5	126
DC shunt motor + DC shunt generator set	1	3.5	126
Alternator + DC compound motor	1	4.5	162
Single phase induction motor	1	0.75	27
Slipring induction motor	1	3.7	133.2
Squirrel cage induction motor	2	3.7	266.4
Induction generator	1	3	108
Double cage	1	3.7	133.2
Pole changing motor	1	3.7	133.2
Cascade Induction motor	2	3.7	266.4
Synchronous induction motor	2	3.7	266.4
Tube	33	0.036	42.768
Fan	18	0.05	32.4
Total			2488.968

3.3.5 Canteen

Working hours:

- Hall 7:30am to 10am; 12:00 to 2:00pm; 3:30pm to 5:20pm; 7:00pm to 9:00pm (9hrs)
- Kitchen 5:00am to 10:00pm (17hrs)

CANTEEN				
Equipment	No:	Power (kW)	Working time	Power consumption/month (kWh)
Mixer grinder	2	0.75	30 mins/day	22.5
Grinder (201)	2	1	4hrs/day	240
Fresh Juicer	1	0.6	30 mins/day	9
Deep freezer	2	0.175	24hrs/day	252
Refrigerator	1	0.042	24hrs/day	30.24
Freezer	1	0.042	24hrs/day	30.24
Dough mixer	1	1.1	20min/day	9.9
Cutting machine	1	0.55	90mins/ day	24.75
Weighing balance	1	0.015	10mins/day	0.075
Billing machine	1	0.023	9hrs/day	6.21
Tube	28	0.036	20 nos-9hrs/day, 8 nos- 17hrs/day	341.28
Fan	17	0.05	9hrs/day	229.5
Total				1195.695




Figure 3.2 Power consumption trend of canteen

From the pie chart shown above it is seen that major power consuming component is tube lights (29%) followed by deep freezer (21%).

3.3.6 Ladies Hostel

Number of rooms occupied = 103

Number of inmates = 296

Students per room = 3(approx.)

Working days = 30

Holidays = nil

Ceiling fan (capacity: 50w)

Total number =103(1 per room + 2 common)

Working hours = 15 hrs (working days)

22 hrs (holidays)

Lighting

Tubelight (36w)

Total number = 224 (2 per room + 22 common)

Working hours = 10hrs (rooms, working days)

8 hrs (rooms, holidays)

15 hrs (common, per day)

<u>LED</u> (15w)

Total number = 12 (bathrooms)

Working hours = 8hrs per day

Plug point

Total number = 206(2 per room)

Laptop charging (50w)

Working hours = 8 hrs

Holidays = 10hrs

Iron box (1100w)

Total number = 30

Working hrs = 15 mins per day (only on working days)

Solar Heater

LCD monitor system (240w)

Total number = 4

Working hours = 4hrs (working days)

8hrs on holidays

Television (128.22 kWh/yr)

Total number = 2

Working hours = 1hrs per day

Water filter (280w)

Number = 2 Working hrs = 5hr

Fridge (360 unit/yr)

Total number = 1

Working hrs = 24hr

Computer

Total number = 1

Equipment	Power consumption/month (kWh)
Ceiling fan	2461.7
Tube light	5983.488
LED	43.2
Plug point	831.6
LCD monitor system	130.56
Computer	138.24
Fridge	360
Water filter	84
Television	384.66
Total	10417.448




Figure 3.3 Power consumption trend of ladies hostel

From the pie chart above we can see that major power consuming component is laptop followed by tube lights and fans.

3.3.7 Junior Men's Hostel

Number of rooms occupied = 59

Number of inmates = 104

Students per room = 3(approx.)

Working days = 24

Holidays = 6

Ceiling fan (capacity: 55w)

Total number = 70(1 per room + 8 in terrace)

Working hours = 15 hrs (working days)

22 hrs (holidays)

6 hrs (terrace)

Lighting

Tubelight (36w)

Total number = 165 (2 per room + 39 common)

Working hours = 10hrs (rooms, working days)

8 hrs (rooms, holidays)

10 hrs (common, per day)

Plug point (50w)

Total number = 114(2 per room)

Working hours = 8 hrs

<u>Iron box</u> (1100w)

Total number = 57

Working hrs = 15 mins per day (only on working days)

Water filter (75w)

Total number = 1

Working hrs = 5hr

Cooler (90w per day)

Number = 1

Equipment	Power consumption/month (kWh)
Ceiling fan	2079
Tube light	1805
Iron box	376.2
Plug point (mobile)	1368
Water filter	11.25
Cooler	2.16
Total	5641.61




Figure 3.4 Power consumption trend of junior men's hostel

3.3.8 Senior Men's Hostel

Number of rooms occupied = 70

Number of inmates = 191

Students per room = 2 - 3 (approx.)

Working days = 24

Holidays = 6

Ceiling fan (capacity: 50w)

Total number = 140 (2 per room)

Working hours = 15 hrs (working days), 22 hrs (holidays)

Lighting

Tubelight (36w)

Total number = 225(2 per room + 85 common)

Working hours = 10hrs (rooms, working days)

8 hrs (rooms, holidays)

8 hrs (common, per day)

<u>CFL</u> (15w)

Total number = 70 (bathrooms)

Working hours = 3hrs per day

Plug point

Total number = 140 (2 per room)

Laptop charging (50w)

Working hours = 8 hrs (working days)

10hrs (holidays)

<u>Iron box</u> (1100w)

Total number = 36

Working hrs = 15 mins per day (only on working days)

Water filter (75w)

Number = 1

Working hrs = 5hr

Cooler (90w per day)

Number: 1

<u>Pump</u>

Number = 1

Working hours = 1.5hrs

Equipment	Power consumption/month (kWh)
Ceiling fan	3080
Tube light	1944

Water filter Cooler	11.25 2.16
Pump (5 HP)	5.59
Total	6282.3




Figure 3.5 Power consumption trend of senior men's hostel

3.3.9. Library

Equipment	No:	Power (kW)	Power consumption/month (kWh)	
AC	10	3.6 604.8		
Computer	18	0.24 40.32		
Printer	1	0.1 7.2		
Scanner	2	0.1	7.2	
CCTV	28	120	8400	
Table fan	7	50	5280	
Invertor	1	10KV	720	
Fan	116	0.05	8.4	

Tubelight	103	0.036	6.048	
Total			15073.968	

3.3.10 Effluent Treatment Plant

Equipment	No:	Power consumption/month (kWh)
Motor (3 HP)	1	1610.71
Motor (2 HP)	4	4295.23
Total		5905.94

TOTAL POWER CONSUMPTION DATA

BUILDING	POWER CONSUMPTION/MONTH (kWh)
Administrative Block	165330.158
Academic Block- I	16638.476
Academic Block – II	3933.514
Laboratory Blocks	5557.132
Canteen	1195.695
Ladies hostel	10417.448
Junior Men's Hostel	5641.610
Senior Men's Hostel	6282.300
Library	15073.968
ETP	5905.940
TOTAL	235976.241




Figure 3.6 Power consumption pattern of different blocks of SSET Campus

4. SOLID WASTE AUDIT

4.1 Scope of Waste Audit

Waste audit encompasses the entire spectrum of waste collection, segregation, reuse, recycle, incineration and landfill. Appropriate suggestions and justifications would be put forth to improve the efficiency of the system as a whole.

4.2 Waste Generation in the Campus

Waste generated in the campus varies from paper, plastic, cloth, glass, food and sanitary items. Their sources include academic blocks, hostels, office, canteen and kitchen. The waste that is generated from all these sources if not handled properly may pose a serious health and environmental hazards. The wastes generated from various activities in the campus are mentioned below.

> CANTEEN

Food waste of 200 kg and vegetable waste of around 30 kg are generated daily from the canteen which are taken to a nearby pig farm. Other wastes including paper, plastic (milk cover = 90 nos., curd cover = 30 nos., masala cover = 15 nos.) and special wastes of 5 kg is generated per day within the canteen.

> ADMINISTRATIVE BLOCK AND ACADEMIC BLOCKS

Rubbish of about 6 kg is collected daily and burnt in garbage burner. Mixed paper wastes including answer sheets, question papers, newspapers, magazines, office papers, used notebooks etc. is generated @ 4.5 ton per year. Mixed paper wastes are sent to SCMS Muttom campus, from where it is taken by Plan@earth for recycling.

> HOSTELS

Wastes including paper, plastic, sanitary items, bags etc. weighing around 10 kg are daily collected and burnt in the garbage burner. Plastic bottles are also taken by Plan @ Earth for recycling.

> E-WASTE

E-waste generated in the campus, which is around 500 kg has been stored in a room in Academic block - I.

4.3 Methodology

SSET campus includes an Administrative block of 6 floors, Academic block-I of 3 floors, Academic block-II of 4 floors, engineering laboratories and workshops, ladies' hostel of 3 floors, junior boys' hostel of 3 floors and a full time working canteen which provides food for around 1000 people at a time. To evaluate the trends of waste generation and waste management techniques adopted at campus, interviews were conducted with the cleaning staff, administrative officers and students. The amount of waste generated, major sources of waste and frequency of waste collection were enquired from the cleaning staff. The details about the sources of waste generation in the campus are shown in Table 4.1.

Table 4.1 Sources of wastes

Sl. No.	Source	Types	
1	Hostels	Paper, plastics, cloth, electronic items, leather, rubber, sanitary.	
2	Academic Areas	Paper, plastic, electronic items, sanitary items, food	
3	Canteen	Food, vegetable wastes, plastics, paper, gunny bags	
4	Office	Paper, plastic	
5	Labs	Concrete blocks, electronic items, paper	

Table 4.2 Frequency of Waste Collection from Various Sources

Sl. No.	Source	Frequency of Collection
1	Academic Blocks	Once a day
2	Hostels	Once a day
3	Canteen	Twice a day
4	Road Side Dustbins	Once a week

Table 4.3 Daily Waste Generated

Sl. No.	Waste Type	Weight (Kg Per day)	Percentage by Weight
1	Food waste, Kitchen wastes	235	89.1
2	Newspaper/mixed papers	9.5	3.7
3	Rubbish (Paper waste, Plastic etc)	19	7.2
4	E-waste	0.25 (90 kg per annum)	0.0009
	Total	263.75	100

WASTE GENERATION STATUS OF THE CAMPUS




Figure 4.1. Percentage by weight of yearly waste generated




Figure 4.2 Waste disposal trend at SSET campus

The SSET, Karukutty campus serves as a living laboratory of sustainable practices by integrating academia, student life and campus operations, researching new solutions through campus practices for sustainable waste management. Students have played a vital role in encouraging environmental consideration in every functional facet of the institution. An efficient management of waste starts with regular collection of waste generated. This task has been made easier by placement of dustbins at appropriate places. Dustbins are placed at canteens, each corridor of all the buildings, roadsides, etc. Covered dustbins are used in order to prevent breeding of infectious vectors. The plastic bottles from the hostels, canteen and campus are sorted by the workers which is further collected by plan @ Earth for recycling. Campus wastes dominantly paper, plastic, thermocole, sanitary, ceramic, etc. which can neither be reused nor recycled and other combustible wastes from each buildings are collected by the cleaning staffs of the campus which is later on burnt in the garbage burner each day.

The SSET, Karukutty campus is now making a conscious effort to establish the campus as a 'zero waste' zone, through a slew of scientific and environment-friendly measures. A number of initiatives have been put in place to promote the concept of 'reduce, reuse and recycle' and contribute mite to protecting the environment.

A) Management of Paper Waste

☐ Carton

Pa	pers are segregated based on the following basic paper grade categories:
	Magazines
	Mixed Paper
	Old Newspapers

Mixed paper is a broad category that often includes items such as discarded mail, telephone books, paperboard and catalogues. High grade deinked paper is made of high grade paper such as letterhead, copier paper, envelopes, and printer and convertor scrap that has gone through the printing process. One-sided used papers are collected and sent back to offices, dispensaries, provisional stores, etc. for reuse as scratch pads. Double-sided used papers are collected, accumulated and sold for recycling by Plan @ Earth.

B) Management of Food Waste.

Food wastes and all other organic wastes from canteen are taken daily to a pig farm located at Idukki. The amount of organic matter being retained at the campus is nil.



Figure 4.3 Tank for removing sediments and floating matter from canteen waste water before reaching ETP

C) Management of Combustible Waste

A garbage burner of capacity 150 kg is installed at the campus in which the combustible wastes like paper, plastic, wrappers, gunny bags, paper bags, clothes, sanitary waste etc are burnt daily. The ashes and residues from the garbage burner are removed once in a month which is used for gardening. No fuel is used for burning the waste.



Figure 4.4 Garbage burner at SSET, Karukutty



Figure 4.5 Green audit team inspecting garbage burner

D) Management of Recyclable Waste

Wastes including newspapers, magazines, cartons, mixed papers and plastic bottles and are collected by Plan @ Earth periodically for recycling. E-wastes from the campus like cabinets, monitors, keyboards, mouse, motherboard, hard discs, switch ports, UPS, CDs, SMPS, LCD projectors, printers, battery etc are presently stored in a room in Academic Block - I

About PLAN @ EARTH

Plan @ Earth is a non-profit organization registered as an NGO at Travancore Cochin Literary. Plan @ earth collects waste paper, plastic and E wastes from the campus and recycles them. Recycling of one ton of paper wastes saves 17 trees, 3.3 cubic metre landfill space and 7000 gallons of water.

SCMS group of educational institutions received a green certificate for saving 144 trees on 2015, 23 trees on 2017, 155 trees on 2019 and 155 trees on 2020 by ensuring recycling of 8482 kg, 1381 kg, 9121 kg and 9112 kg of used paper respectively; also 1250 kg E-waste recycled in 2019 through WOW (Wealth Out of Waste) project by Plan @ Earth.

This Green Certificate Granted on June 5th 2015 states that S.C.M.S. Group. D. Education. Anstitution by recycling
by recycling&H.8.2 Kilos of paper has saved
And reduced "greenhouse gas emissions by

Figure 4.6 Green certificate awarded to SCMS in 2015




Figure 4.7 Green certificate awarded to SCMS in 2017



Figure 4.8 Green certificate awarded to SCMS in 2019




Figure 4.9 Green certificate awarded to SCMS in 2020

5. Summary of Findings & Recommendations

5.1 Audit recommendations for potential water saving

Based on the information collected and observations, the following can be recommended to reduce water use and increase its efficiency.

- Replacement of single flush cisterns with dual flush cisterns At present the toilet commodes have 10 litre flush which can be replaced with 3/6 litres or 2/4 litres dual flush cisterns. Dual flush WCs operate on a split button with the user having the option of which one to use. Usually the smaller button operates the shorter flush of 3 litres which is adequate for flushing liquid waste, while the larger button is for 6 litres flush for more substantial waste. This can reduce water use by around 30-40%.
- Extent the rainwater harvesting facility to academic blocks one and two which helps to increase the water quality, especially to reduce the iron content.
- > Separate treatment facility for kitchen sullage and recycle treated waterThe water use diagram shows that kitchen sullage is a dominant fraction of waste water, which if sought a separate treatment, can be recycled for flushing purposes with more acceptance from the staff and students.
- Flush with grey water: Use runoff water for flushing purpose.
- Establish a water budget for the building and, set and monitor performance criteria.
- Awareness to the students and staff regarding the importance of conservation of water.
- ➤ Install treatment facility for the removal of excess iron from ground water.
- Introduce water meters in the flush water line: Flushing is a major water use activity as found from the household survey. However, SSTM is not metering the flush water line at the moment. Meters may be introduced in the flush water line to prevent any misuse. It is better to utilize the excess rainwater collected than let it go wasted.
- Awareness to the students and staff regarding the importance of conservation of water.
- > Incentives for those who consumes less water.
- Use of vacuum cleaners for housekeeping.

5.2 Audit recommendations for potential Energy saving

- All air conditioned rooms can be provided with doors having automatic closing mechanism and windows with tinted glass to reduce load on the air conditioning system.
- Good light ventilation and Air ventilation to classrooms without air conditioning system to avoid the use of tube lights and minimize the use of ceiling fans at high speed. Currently most of the classrooms are having window curtains. Avoid using curtains to facilitate entry of sunlight.
- It is recommended that fluorescent lamps in corridors and toilets may be replaced with CFL or LED light at the end of utility period of currently installed fluorescent lamps as it consumes much less energy compared to fluorescent lamps.
- Install ceiling fans in faculty rooms which currently have only air conditioning system. Use air conditioners only during summer.
- Let the good practice of replacing of CRT monitor with LED monitors to be continued. LED monitors typically require about 20% of the power required for a CRT monitor with the same screen area. In addition, the amount of heat generated by an LED monitor is considerably less than a CRT monitor, resulting in a lower load on air conditioning. Building cooling needs may be decreased by up to 20%.
- Switch off the photocopier machine at the main outlet itself when not in use or in other words machine should not be kept in stand by and sleep mode which consumes power.
- Do not leave laptop/ mobile charger on throughout the night.
- Reduce wastage of water and thereby the power required to pump up the water can be cut down.
- Switch on heater only when required.
- Switch of water cooler during night time.
- If the elliptical trainer or treadmill in the gym is connected to a device that can convert the output into electricity, it might deliver 10 Calories per minute, which translates to 700 watts or the power consumption of seven good light bulbs.

- If the sports bike of the gym is connected to a device that can convert the output into electricity, we can generate about 50 watt-hours per half-hour of cycling at a moderate pace. That is good enough to keep an efficient light bulb illuminated for an hour.
- Since a large amount of food waste is generated in the canteen, installation of a biogas plant can be a better solution for waste disposal as well as energy recovery.
- From the discussions with the authorities, it is understood that the institution has already initiated steps with KSEB for installing solar panels which will reduce power consumption.

5.3 Audit recommendations for waste management

- Place dustbins with different colour codes, so that waste can be separated into different types like (plastic, paper, food etc.) at source itself.
- Provide more dustbins in gardens, corridors, roadsides, and canteen and make students more aware of using it effectively.
- Use covered dustbins instead of open dustbins in order to prevent breeding of infectious vectors.
- The waste collected from various places in the campus for burning in garbage burner,
 may be kept in closed pits or in storage rooms.
- May think of steps to recycle the plastic waste generated in campus by collaborating with Kerala government's 'Suchitwa Mission' project.
- Awareness among students and staff to reduce wastage of food in the canteen.
- Encourage reuse of one-side printed papers for less important documentation or for reuse as scratch pads in offices and faculty rooms.
- Sorting the waste before garbage burning should be given utmost priority.
- Existing initiative for recycling paper and e-waste in association with plan@earth in very good and may be sustained.